



tecna[®]
acondicionamiento de aguas **s.a.**

**TABLA DE EQUIVALENCIAS ENTRE EL NÚMERO DE GOTAS GASTADAS Y LOS PPM DE
TECNA 485 EN EL CIRCUITO**

Nº gotas gastadas	ppm en el circuito	Nº gotas gastadas	ppm en el circuito
1	2.16 ppm	26	56.16 ppm
2	4.32 ppm	27	58.32 ppm
3	6.48 ppm	28	60.48 ppm
4	8.64 ppm	29	62.64 ppm
5	10.80 ppm	30	64.80 ppm
6	12.96 ppm	31	66.96 ppm
7	15.12 ppm	32	69.12 ppm
8	17.28 ppm	33	71.28 ppm
9	19.44 ppm	34	73.44 ppm
10	21.6 ppm	35	75.60 ppm
11	23.76 ppm	36	77.76 ppm
12	25.92 ppm	37	79.92 ppm
13	28.08 ppm	38	82.08 ppm
14	30.24 ppm	39	84.24 ppm
15	32.40 ppm	40	86.40 ppm
16	34.56 ppm	41	88.56 ppm
17	36.72 ppm	42	90.72 ppm
18	38.88 ppm	43	92.88 ppm
19	41.04 ppm	44	95.04 ppm
20	43.2 ppm	45	97.20 ppm
21	45.36 ppm	46	99.36 ppm
22	47.52 ppm	47	101.52 ppm
23	49.68 ppm	48	103.68 ppm
24	51.84 ppm	49	105.84 ppm
25	54 ppm	50	108.00 ppm